



NOTES

1. BLOWER MUST BE WITHIN 100 FEET OF FAST UNIT. FOR DISTANCES GREATER THAN 100 FEET — CONSULT FACTORY. BLOWER MUST BE LOCATED ABOVE NORMAL FLOOD LEVELS.
2. VENT TO BE LOCATED ABOVE FINISH GRADE OR HIGHER TO AVOID INFILTRATION. SECURE 6" VENT GRATE (NDS 6-034 W/7.1 SQ. IN. OPEN SURFACE AREA OR EQUIVALENT) WITH STAINLESS STEEL SCREWS.
3. RUN VENT TO DESIRED LOCATION AND COVER OPENING WITH 3" VENT GRATE. SECURE WITH SCREWS. VENT MUST NOT ALLOW EXCESS MOISTURE OR PRESSURE BUILDUP.

ALL APPURTENANCES TO FAST UNIT (e.g. SEPTIC TANK, PUMP OUTS, ETC.) MUST CONFORM TO ALL COUNTRY, STATE, PROVINCE AND LOCAL CODES.

4. BLOWER CONTROL SYSTEM BY BIO-MICROBICS, INC.
5. COPYRIGHT (C) 2003, BIO-MICROBICS, INC.
6. FAST MODULE MUST BE SECURED BY BOLTING THROUGH THE STRAPS, THEN THE LID IS BOLTED TO THE TANK. NOTE: ANCHOR BOLTS NOT PROVIDED. NOTE: STRAP DIMENSIONS: 37" L x 9" W, 2 STRAPS TOTAL.
7. EFFLUENT HOLE WILL ACCEPT A 3" SCH 40 PVC PIPE WHICH CAN THEN BE INSERTED INTO THE EXISTING 4" DISCHARGE PIPE IN THE SEPTIC TANK.

DRAWN	jdu
SCALE	
DATE	12/20/04
APPROVED	

7125 East Pickard Road
P. O. Box 309
Mt. Pleasant, MI 48804-0309
ph-989-773-9938
fax-989-772-3415



BY	DATE	REVISION
jdu	12/04	1.
SLB	6/08	2.
		3.
		4.
		5.

NO	1.	2.	3.	4.	5.
SHEET	OF 2				

RetroFAST® 0.375 L

DRAWING NO. M7